

**Building Technology Services,  
Inc**

13833 Wellington Trace E4-157  
Wellington, Florida 33414

# Invoice

Date	Invoice #
5/10/2012	6712

<b>Bill To</b>
Center Realty Associates 60 Pompton Ave Verona, NJ 07044

<b>Ship To</b>
6702 Via Regina Deerfield Beach, FL. 33433

<b>P.O. No.</b>	<b>Terms</b>	<b>Project</b>
	Net 30	

Quantity	Description	Rate	Amount
1	Service Call-5/7/2012; System freezing up. Found home at 73 degrees with no ice on coil. Checked system operation & found all to be normal. System operating pressures were however in the lower end of the acceptable range. This combined with tenant's usage habits (low setpoints) seem to be the only plausible explanation for system freezing. Added (3) lbs. of R-22 to raise charge to higher end of acceptable operating pressures thereby reducing the chances of future freezing.	72.00	72.00
3	R22 REFRIGERANT LBS	23.00	69.00
	Sales Tax	6.00%	4.14

Thank you for your business.	<b>Total</b>	\$145.14
------------------------------	--------------	----------

Phone # 561-712-1126	Fax # 561-712-1407	ccampbell_bts@bellsouth.net
----------------------	--------------------	-----------------------------