



**Building Technology Services, Inc**  
 13833 Wellington Trace E4-157  
 Wellington, Florida 33414

# Invoice

Date	Invoice #
12/5/2013	92372

**Bill To**

2201 Corporate Realty Associates, LLC  
 2201 NW Corporate Blvd., #203  
 Boca Raton, FL. 33431

**Ship To**

2201 NW Corporate Blvd.  
 Boca Raton, FL. 33431

<b>P.O. No.</b>	<b>Terms</b>	<b>Project</b>
	Net 30	

Quantity	Description	Rate	Amount
1	Service call-11/14/13; Check a/c-"building feels humid". Found a/c unit working properly. Cooler outside air temps cause a/c to run fewer compressors which causes less humidity to be removed from the building.	72.00	72.00
1.5	Service call-11/27/13; Check a/c unit, server room a/c, suites 108, 103, & 101. A/C unit running properly. Lowered a/c setpoint to 73 deg. F at mgmt. request. Server room a/c and suites all no trouble found.	72.00	108.00
1	Service labor-12/5/13; Replace pneumatic thermostat in rear office of suite 101.	72.00	72.00
1	Barber-Colman r/a pneumatic thermostat	160.00	160.00
	Sales Tax	6.00%	9.60

Thank you for your business.	<b>Total</b>	\$421.60
------------------------------	--------------	----------

Phone # 561-712-1126 Fax # 561-712-1407 accounting@bts-ac.com