

**Building Technology Services,**

**Inc**

13833 Wellington Trace E4-157

Wellington, Florida 33414

# Invoice

Date	Invoice #
12/18/2012	25849

<b>Bill To</b>
2201 Corporate Realty Associates, LLC 2201 NW Corporate Blvd., #205 Boca Raton, FL. 33431

<b>Ship To</b>
2201 NW Corporate Blvd. Boca Raton, FL. 33431

P.O. No.	Terms	Project
	Net 30	

Quantity	Description	Rate	Amount
1	Service call-12/18/2012; No trouble with equipment but humidity was building inside the offices due to the fact that the a/c compressors were running at minimal capacity because the outside air temp was 74 deg. F, return air temp was 73 deg. F, and setpoint was 72 deg. F. I lowered the setpoint to 70 deg. F to alleviate the problem. We will probably want to raise the setpoint to 72 deg. F when the hot weather returns.	72.00	72.00
	Sales Tax	6.00%	0.00

Thank you for your business.	<b>Total</b>	\$72.00
------------------------------	--------------	---------

Phone # 561-712-1126	Fax # 561-712-1407	ccampbell_bts@bellsouth.net
----------------------	--------------------	-----------------------------