



1
(LIFE SAFETY) FLOOR PLAN
1/8" = 1'-0"



2
FIRE PROTECTION PLAN
1/8" = 1'-0"

- WALL LEGEND**
- EXIST PARTITION TO REMAIN
 - NEW 1/2" GIBB PARTITION
 - NEW 1" FIRE RATED PARTITION
 - [F.E.]** INDICATES NEW 10 LB. ABC TYPE FIRE EXTINGUISHER WITH HANGER BRACKET

- * ALL FURNITURE TO BE PROVIDED BY TENANT
- 1. ALL UNRATED FIRE PARTITIONS TO HAVE THE ABOVE FIRE AND SMOKE BARRIERS. PROTECT ALL OPENINGS PERMANENTLY STENCILED ON THE PARTITION ABOVE THE SUSPENDED CEILING. CHARACTERISTICS SHALL BE AT LEAST 1" FINCHES IN HEIGHT. IDENTIFICATION SHALL BE SPACED NOT MORE THAN 15" ON CENTER.
- 2. PENETRATIONS THROUGH A FIRE-RATED WALL ASSEMBLY SHALL BE PROTECTED BY A FIRE-STOP SYSTEM OR DEVICE.
- 3. PROVIDE TACTILE SIGNAGE AT REQUIRED EXIT DOORS WITH EXIT SIGNS.

SPRINKLER HEAD

| SYMBOL | TYPE | TEMP | SIZE |
|--------|------------------------------|------|------|
| ● | QUICK TYPE CONCEALED REEDANT | 167° | 1/2" |

* FIRE SPRINKLER SHOP DRAWINGS ARE TO BE SUBMITTED UNDER A SEPARATE FIRE SPRINKLER PERMIT.
* COMPLY WITH NFPA 13 2010 EDITION