GENERAL MECHANICAL NOTES

- ALL SUPPLY, RETURN, EXHAUST, AND OUTSIDE AIR DUCTWORK SHALL BE CONSTRUCTED OF GALVANIZED SHEET METAL, UNLESS NOTED OTHERWISE ON PLANS. DUCTS SHALL BE FABRICATED IN COMPLIANCE WITH SMACNA "HVAC DUCT CONSTRUCTION STANDARDS METAL AND FLEXIBLE." REFER TO THE PROJECT SPECIFICATIONS FOR PRESSURE CLASSIFICATION AND SEALING REQUIREMENTS. SEAL ALL DUCTWORK TO SEAL CLASS 'A'. ALL LONGITUDINAL SEAMS 12" AND LARGER ARE TO BE PITTSBURGH LOCK TYPE.
- REFER TO SPECIFICATIONS FOR INSULATION REQUIREMENTS OF SUPPLY, RETURN, TRANSFER,

RELIEF AND OUTSIDE AIR DUCTWORK.

- EXACT LOCATION OF AIR DISTRIBUTION DEVICES SHALL BE COORDINATED WITH THE LIGHTS, SPRINKLER HEADS AND WITH THE SUSPENDED CEILING TILES, AND AS SHOWN ON THE ARCHITECTURAL REFLECTED CEILING PLANS..
- PROVIDE ACCESS DOORS AT ALL FIRE DAMPERS, SMOKE DAMPERS, COMBINATION FIRE/SMOKE DAMPERS, DUCT HEATERS, AND AUTOMATIC TEMPERATURE CONTROL DEVICES WITH MAXIMUM ALLOWABLE STANDARD SIZE PERMITTED BY DUCT DIMENSIONS. DOORS SHALL HAVE SAFETY CHAIN WITH CAM LATCHES AND FULLY GASKETED TO THE PERIMETER. PROVIDE ACCESS PANELS IN CEILING WHERE REQUIRED TO PROVIDE ACCESS TO DAMPERS, DUCT HEATERS AND SIMILAR DEVICES.
- COORDINATE INSTALLATION WITH ALL OTHER INVOLVED TRADES. IN THE CASE OF CONFLICT BETWEEN DRAWINGS AND SPECIFICATION, THE MORE STRINGENT REQUIREMENT AS DETERMINED BY THE ENGINEER SHALL TAKE PRECEDENT.
- FLEXIBLE AIR DUCT SHALL BE USED FOR RUNOUTS BETWEEN THE SUPPLY AND RETURN AIR DUCTS AND AIR DISTRIBUTION DEVICES WHERE INDICATED. FLEXIBLE DUCT SHALL BE A MINIMUM OF SIX MAXIMUM OF FOURTEEN FEET IN LENGTH AND OF THE MYLAR-COATED WIRE HELIX TYPE WITH 1" THICK FIBERGLASS INSULATION AND METALIZED MYLAR LAMINATE VAPOR BARRIER COVER. ATTACH FLEXIBLE AIR DUCT TO DIFFUSERS AND SPIN COLLARS WITH PLASTIC OR METAL DRAW BANDS AND SEAL THE ENDS WITH TAPE AND MASTIC TO MAINTAIN THE VAPOR BARRIER. FLEXIBLE DUCT AND SPIN COLLAR SIZE SHALL BE THE SAME NOMINAL DIAMETER AS THE NECK OF THE AIR DISTRIBUTION DEVICE IT IS CONNECTED TO. FLEXIBLE DUCT SHALL BE ONE—PIECE AND NOT BE SPLICED TOGETHER.
- ELEVATIONS GIVEN: B.E. = BOTTOM ELEVATION, C.E. = CENTERLINE ELEVATION, T.E. = TOP ELEVATION, ARE TAKEN FROM THE CONCRETE FLOOR SLAB. THESE ELEVATIONS ARE APPROXIMATE AND MUST BE VERIFIED IN THE FIELD BY THE CONTRACTOR PRIOR TO FABRICATION OF ANY DUCTWORK.
- PROVIDE SINGLE THICKNESS METAL TURNING VANES IN ALL SQUARE ELBOWS INCLUDING SUPPLY, RETURN, EXHAUST AND OUTSIDE AIR DUCTS. WHERE UNEQUAL SQUARE ELBOWS ARE SHOWN, TURNING VANES WITH TRAILING EDGE EXTENSIONS SHALL BE USED.

- DOCUMENTS ARE SCHEMATIC IN NATURE AND DO NOT INDICATE EVERY BEND, ELBOW, OR OFFSET REQUIRED IN DUCTWORK AND PIPING. FIELD VERIFY ALL DUCTWORK SIZES AND ELEVATIONS PRIOR TO FABRICATION/INSTALLATION. PROVIDE MODIFICATIONS WHERE REQUIRED FOR COORDINATION IN BASE CONTRACT PRICE AT NO ADDITIONAL COST.
- ENDS OF DUCTWORK AND PIPING SHALL BE KEPT SEALED USING PLASTIC SHEETING AND DUCT TAPE DURING CONSTRUCTION.
- EQUIPMENT SHALL BE SUPPLIED AND INSTALLED WITH PROVISION FOR IN-PLACE CLEANING AND SIMILAR MAINTENANCE TASKS IN ACCORDANCE WITH THE REQUIREMENTS OF ASHRAE 62-1999.
- PROVIDE MISCELLANEOUS STRUCTURAL STEEL TO SPAN ACROSS BEAMS, JOISTS AND PURLINS WHERE REQUIRED FOR INTERMEDIATE SUPPORT.
- OUTDOOR AND EXHAUST AIR DUCTS SHALL BE SLOPED TOWARDS THE INTAKE OR EXHAUST LOUVERS.
- THE CONTRACTOR IS TO CLEAN, PRIME, AND PAINT FLAT BLACK THE INSIDE OF ALL DUCTWORK THAT IS VISIBLE THROUGH ANY LOUVER OR AIR DEVICE.
- LOCATIONS FOR TEMPERATURE AND HUMIDITY SENSORS ARE APPROXIMATE IN NATURE AND SHALL NOT BE SCALED FROM THE DRAWINGS. COORDINATE EXACT LOCATIONS WITH ROOM FURNITURE LAYOUT AND CONFIRM PROPOSED LOCATION WITH THE OWNER'S REPRESENTATIVE
- FOR ALL MANUAL VOLUME DAMPERS LOCATED ABOVE A HARD CEILING OR INACCESSIBLE CEILING, PROVIDE A REMOTE CABLE OPERATED DAMPER ACTUATOR ASSEMBLY MOUNTED IN THE CEILING, EQUAL TO "YOUNG REGULATOR".

SHEET LIST TABLE

EQUIPMENT MARK DESIGNATION					
CD CEILING DIFFUSER EG EXHAUST GRILLE RG RETURN GRILLE SG SIDEWALL GRILLE TG TRANSFER GRILLE	CD-X XXX AIR QUANTITY IN CFM (CUBIC FEET PER MINUTE)				
AHU = AIR HANDLING UNIT SF = SUPPLY FAN EF = EXHAUST FAN CU = CONDENSING UNIT CV = CONTROL VALVE TB = VAV TERMINAL BOX	AIR HANDLING UNIT DESIGNATION UNIT NUMBER				

			SHEET NUMBER	SHEET TITLE
	_ UNIT		M-0.1	LEGEND, GENERAL NOTES, AND SCHEDULE
USER RILLE LLE	NUMBER CD-X		M-0.2	MECHANICAL SCHEDULES
		M-1.1	ADMINISTRATION MECHANICAL HVAC PLAN - DEMOLITION	
RILLE	XXX		M-1.2	ADMINISTRATION MECHANICAL HVAC PLAN - NEW WORK
RILLE	L AIR QUANTITY IN CFM (CUBIC FEET PER MINUTE)			
DUNC UNIT				
DLING UNIT AN FAN NG UNIT VALVE INAL BOX	AIR HANDLING UNIT DESIGNATION UNIT NUMBER			
		ļ		

DUCTWORK SIZE COORDINATION

NEW DUCTWORK SHOWN IN CONCEALED LOCATIONS SHALL BE FIELD VERIFIED BY THE CONTRACTOR PRIOR TO FABRICATION. IF A DUCT SIZE IS DETERMINE TO BE NEEDED TO BE REVISED, THE CONTRACTOR SHALL ISSUE AN RFI AND NOTIFY THE ENGINEER TO ASSIST IN DETERMINING AN ALTERNATIVE DUCT SIZE.

	STRUC STRUC STRUC STRUC
	Z CON S
T F	COPYRIGHT 2012 THESE DRAWINGS ARE FOR THE EXCLUSIVE USE OF GLIDDEN SPINA & PARTNERS, INC. AND MAY NOT BE DUPLICATED, REPRODUCED OR USED





XPRESS WRITTEN CONSENT OF CLIDDEN SPINA & PARTNERS, INC