

**H.V.A.C. SCHEDULE**

MANUF. UNIT #1	FLORIDA HEAT PUMP
A.H.U.:	REAB-1605 BYS
SEER:	10.50
VOLTAGE:	240
PHASE:	1 Ø
B.T.U. COOL:	47,100
B.T.U. HEAT:	34,130
HEAT STRIP:	10 KW.






MANUF. UNIT #2	FLORIDA HEAT PUMP
A.H.U.:	REAB-1605 BYS
SEER:	10.50
VOLTAGE:	240
PHASE:	1 Ø
B.T.U. COOL:	47,100
B.T.U. HEAT:	34,130
HEAT STRIP:	10 KW.

MANUF. UNIT #3	FLORIDA HEAT PUMP
A.H.U.:	REAB-1605 BYS
SEER:	10.50
VOLTAGE:	240
PHASE:	1 Ø
B.T.U. COOL:	47,100
B.T.U. HEAT:	34,130
HEAT STRIP:	10 KW.

RELOCATED MANUF. UNIT #4	FLORIDA HEAT PUMP
A.H.U.:	REAB-1605 BYS
SEER:	10.50
VOLTAGE:	240
PHASE:	1 Ø
B.T.U. COOL:	47,100
B.T.U. HEAT:	34,130
HEAT STRIP:	10 KW.

MANUF. UNIT #5	FLORIDA HEAT PUMP
A.H.U.:	REAB-1605 BYS
SEER:	10.50
VOLTAGE:	240
PHASE:	1 Ø
B.T.U. COOL:	47,100
B.T.U. HEAT:	34,130
HEAT STRIP:	10 KW.

**MECHANICAL PLAN**



**LINEAR DIFFUSER SCHEDULE**

MANUF. UNIT #	MANUF. NUMBER	MANUF.	LENGTH	CFM	DUCT FREQ.
R-2	CT-480	TITUS	2'-0"	80	6" ROUND
R-4	CT-480	TITUS	4'-0"	208	2'-6" ROUND
S-1	CT-481	TITUS	2'-0"	52	6" ROUND
S-2	CT-481	TITUS	2'-0"	80	6" ROUND
S-4	CT-481	TITUS	4'-0"	208	2'-6" ROUND

*HVAC by Owner*