



CODE COMPLIANCE NOTE:
 1. THE GOVERNING CODE WILL BE THE 2007 EDITION OF THE FLORIDA FIRE PREVENTION CODE.
 2. THE FIRE ALARM SYSTEM MUST COMPLY WITH THE 2002 EDITION OF NFPA 72.

GENERAL NOTES:
 1. INSTALL DEVICES PER NEW FLOOR PLAN. ADDITIONAL DEVICES MAY BE REQUIRED BY FIRE MARSHAL. ADD THESE DEVICES TO FLOOR PLAN.
 2. WIRE ALL DEVICES BACK TO FIRE ALARM PANEL AND RISE SYSTEM TEST.
 3. ANY MODIFIED TONES SHALL BE ESTABLISHED AND APPROVED BY FIRE ALARM COMPANY AND FIRE DEPARTMENT.

SYMBOL	DESCRIPTION
□	SILENT KNIGHT DUE CAST METAL (SINGLE OR DUAL ACTION)
⊗	SYSTEM SENSOR STROBE (SINGLE OR DUAL ACTION)
⊗	SYSTEM SENSOR STROBE (SINGLE OR DUAL ACTION)
⊗	SYSTEM SENSOR 100 SERIES LOW VOLTAGE PULSING SMOKE DETECTORS
⊗	SYSTEM SENSOR DA/DO DUCT SMOKE DETECTORS
⊗	SILENT KNIGHT BY HONEYWELL INTELLIKNIGHT MODEL STROBE FIRE ALARM CONTROL PANEL
⊗	CONTROL RELAY

FIRE ALARM NOTES:
 1. ALL EQUIPMENT TO BE UL LISTED FOR FIRE SERVICE.
 2. FIRE ALARM WIRING SHALL NOT EXCEED 40% FILL OF CONDUIT.
 3. ALL FIRE STOP PENETRATORS SHALL BE MADE WITH APPROVED (NFC) ELECTRICAL TUBING.
 4. ALL FIRE STOP PENETRATORS SHALL BE SEALED WITH A UL APPROVED FIRE STOP MATERIAL.
 5. ROUTING OF THE FIRE ALARM SYSTEM CONDUIT IS DIAGRAMMATIC. VERIFY EXACT LOCATIONS PRIOR TO STARTING WORK.
 6. ALL STROBE LIGHTS SHALL ACTIVATE UPON INITIATION OF THE GENERAL ALARM, AND SHALL BE SYNCHRONIZED IN OPEN AREAS.
 7. MOUNT FIRE ALARM SYSTEM HORN/STROBES AT 80" A.F.F. OR 6' BELOW CEILING WHICH EVER IS LOWER.
 8. MOUNT FIRE ALARM SYSTEM STROBES AT 80" A.F.F. OR 6' BELOW CEILING WHICH EVER IS LOWER.
 9. THIS SYSTEM SHALL BE INSTALLED BY A UL CONTRACTOR CAPABLE OF PROVIDING A UL CERTIFICATE FOR THE PROPERTY.
 10. CONNECT NEW DEVICES FOR OPERATION AS REQUIRED.

FIRE ALARM PLAN
 SCALE: 1/4" = 1'-0"

PERMIT SET: 01/26/12

NOTE: REVISION CHANGES TO THE SYSTEM COVERED BY THESE PLANS WITHOUT THEIR APPROVAL. OF THE ENGINEER WHO PREPARED THESE PLANS. WILL NULL AND VOID THESE PLANS AND THE REVISIONS ASSOCIATED WITH RETURNING THE SYSTEM TO ITS ORIGINAL DESIGN WILL BE THE RESPONSIBILITY OF THE COMPANY WHICH APPROVED THESE CHANGES. PERMITS ARE TO INCLUDE THESE CHANGES.

FORMICA & ASSOCIATES, INC.
 Consulting Engineers
 3500 N.W. Boca Raton Blvd.
 Suite #771 33431
 Boca Raton, FL 33487
 TEL: (561) 368-4833
 Fax: (561) 368-4733
 Robert F. Formica, P.E., License #19723
 Email: rformica@formicaengineering.com

revisions no.	date
0	//

designed: NM/CH/AF/AL
 drawn: NW
 checked: BFT
 date: 07/26/2012
 scale: AS NOTED
 job no.: 212004

Shawn M. Shumbaugh, PE
 P.E. Lic. #1850 - CA 26210

CLUBHOUSE UNIVERSITY DAYCARE
 JUPITER FARMS SHOPPING CENTER
 PALM BEACH COUNTY, FLORIDA

project
 ARCHITECTURAL
Strandberg, Inc.

Architecture
 Planning

300 Avenue of Champions
 Suite 320
 Palm Beach Gardens, Florida 33418
 Phone 561.202.6990
 Fax 561.296.2194
 archinfo@aol.com