

# Catalfumo Construction, L.L.C.

## REQUEST FOR INFORMATION

No. 00043

4300 Catalfumo Way  
Palm Beach Gardens, FL 33410

Phone: (561) 694-300  
Fax: (561) 691-3890

TITLE: Bath tub drain at Master Bethroom.

DATE: 01/25/2007

PROJECT: CNRI - Cannonsport, LLC

JOB: 06-006-01

TO: Attn: Brian Hayes  
Acock Associates Architects  
383 North Front Street  
Columbus, OH 43215  
Phone: 614-228-1586 Fax: 614-228-2780

STARTED: 01/25/2007

COMPLETED:

REQUIRED: 02/01/2007

### REQUEST:

The answer to RFI No. 00019 changed the bath tub due to the reduce space to fit in according to the contract drawings.

The new bath tub has the drain trap located in different area that interfere with the duct work under the slab. Could you please review and give us the instructions how to proceed?

DWGs P1-2 and H1-2

Requested By: Catalfumo Construction, L.L.C.

Date: 01.25.07

Signed: Gabriel Clavijo

Gabriel Clavijo

Expedition 3

### ANSWER:

PLEASE ROTATE THE TUB 180° SO THAT THE  
CONTROLS & DRAIN ARE ON THE OPPOSITE END  
OF WHAT IS SHOWN IN RFI 00019.

Answered By: Acock Associates Architects


Date: 01-29-07

Signed: Brian Hayes

Brian Hayes


RFI No 00043

①




REVISED MASTER BATH TUB PLATFORM  
RFI # 00019

BUNDLING 143



H-1-2



P1-2